



Technical approval-with-product certificate **K5119/07**

Issued 2020-15-04

Replaces K5119/06

Page 1 of 3

CERTIFICATE

Hep2O system

STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Wavin Limited

as specified in this technical approval-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in this technical approval-with-product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 C "Plastics piping systems of PB intended for the transport of cold and heated drinking water" dated 15-12-2011 inclusive amendment sheet dated 10-03-2015.

Within the framework of this technical approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the plastics piping system, nor the manufacturing of the plastics piping system itself.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273

Postbus 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

info@kiwa.nl

www.kiwa.nl

Company

Wavin Limited

Edlington Lane, Edlington

DN12 1BY DONCASTER

United Kingdom of Great Britain and Northern Ireland

Tel. +44 (0)1709 856300

Fax +44 (0)1709 856301

www.wavin.co.uk



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Hep2O system

PRODUCT SPECIFICATION

Plastics piping systems of PB intended for the transport of cold and heated drinking water according to BRL-K536 part C.

The system consists of:

- PB multilayer pipe colour: (inner / outer): white/white with EVOH barrier layer (5 layer);
- Fittings: mechanical PB fittings of the type Hep2O and Hep2O G4, white;
- Fittings: mechanical female PPSU wall plate elbow fittings, bone colour;
- Fittings: metal.

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)	Hep2O G4 fittings	Metal fittings	female wall plate elbow fittings
15	1,7	X	X	X
22	2,0	X	X	X
28	2,6	X	X	-

Remarks:

- The connections of plastics are push fit and no special tools are required.
- The screw fitting part is not applied to certified PB pipes and will therefore not be certified for the mechanical requirements according to BRL K536 part E & BRL 5604.

Fitness for contact with drinking water



The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"), published in the Government Gazette. The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products are marked with the Kiwa-mark.

Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  * + Class 2/ 10 bar;
- The manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- Material identification: PB;
- The build-up of the pipe; i.e. PB/EVOH/PB;
- Nominal outside diameter and nominal wall thickness of the pipe in mm;
- Production code.

Location of the marks: on every pipe at intervals of not more than 2 m.





The realisation of the marks is as follows: clear durable and indelible.

*) for smaller diameters permitted by Kiwa.

Hep2O system

Fittings


The minimum required marking on the fittings shall be:

- **KIWA**  or on small products  or  or **KK*** or **KK*** (if not possible **KIWA**  only on the smallest packaging unit)**;
- Manufacturer's name, trade name or logo;
- Nominal outside diameter of the corresponding pipe in mm;
- Production code.

Location of the marks: on every fitting.

The realisation of the marks is as follows: clear, durable and indelible.

The smallest packaging unit of the fittings are provided with at least the following information:

- **KIWA**  ;
- Manufacturer's name, trade name, system name, logo or certificate number of the accompanying technical approval (system)certificate, in accordance with the marking of the connecting pipe;
- Nominal outside diameter and nominal wall thickness of the corresponding pipe in mm;
- Material identification in case the fitting body is made of plastics.

Location of the marks: on every package.

The realisation of the marks is as follows: clear, durable and indelible.

*) for small fittings marking with only KK is permitted

***) only after approval by Kiwa

Protection pipes

The minimum required marking on the protection pipes shall be:

- Kiwa (or Kiwa® word mark);
- The manufacturer's name, trade name, certificate number of the protection pipe or the certificate number of the belonging technical approval (system)certificate.

The realisation of the marks is as follows: clearly and indelible at intervals of not more than 2,5 m.

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The medium pipes and fittings are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of NEN-ISO 10508 and an allowable working pressure of maximum 10 bar.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Wavin Limited
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.