



## Product certificate K5139/05

Issued 2020-04-15

Replaces K5139/04

Page 1 of 3

# CERTIFICATE

### PB Pipes

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Wavin Limited

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K536 C "Plastics piping systems of PB intended for transport of hot and cold drinking water" dated 15-12-2011, inclusive amendment sheet dated 10-03-2015.

Ron Scheepers  
Kiwa

*This product certificate is only valid in combination with a Kiwa certified plastics piping system.  
Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

**Kiwa Nederland B.V.**  
Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Certificate holder**  
Wavin Limited  
Edlington Lane, Edlington  
DN12 1BY DONCASTER  
United Kingdom  
Tel. +44 (0)1709 856300  
Fax +44 (0)1709 856301  
[www.wavin.co.uk](http://www.wavin.co.uk)

**Production Location**  
Wavin Limited  
Edlington Lane Edlington  
DN 12 1 BY DONCASTER  
United Kingdom  
T +44 (0)1709 856300  
F +44 (0)1709 856301

**Importer**  
Wavin Netherlands B.V.  
J.C. Kellerlaan 3  
7772 Hardenberg  
The Netherlands  
T +31 (0)523 288911  
F +31 (0)523 288546



**Certification process consists of initial and regular assessment of:**

- quality system
- product

## PB Pipes

---

### PRODUCT SPECIFICATION

5 layer PB pipes according to BRL-K 536 part C: Plastics piping systems of PB intended for the transport of cold and heated drinking water.

The pipe dimensions as indicated in the table below belong to this certificate.

Nominal outside Diameter (mm)	Wall thickness (mm)
15	1,7
22	2,0
28	2,6

Barrier layer pipe (inner / outer): white/white.

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.



The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The products are marked with the Kiwa-mark.

### Pipes

The minimum required marking on the pipes shall be:

- **KIWA**  or  \* + Class 2 / 10 bar;
- the manufacturer's name, trade name, system name, logo or certificate number of accompanying technical approval (system)certificate;
- material identification: PB;
- the build up of the pipe: PB/EVOH/PB;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

Location of the marks: on every pipe at intervals of not more than 2 m.

The realization of the marks is as follows: clear durable and indelible.

\*) for smaller diameters permitted by Kiwa

### LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

### APPLICATION AND USE

The medium pipes and fittings are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of NEN-ISO 10508 and an allowable working pressure of maximum 10 bar.

## PB Pipes

---

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Wavin Limited
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.